



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 3/15/10

Code 50.5.6-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title Table R502.3.3(2) Cantilever Spans For Floor Joists Supporting Exterior Balcony		Page 1 of 1
Proponent William Fox / IBA	Title Code Committee Member	
Address 6125 W 29 th Place, Speedway, IN. 46224		Phone 317-291-7575
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>Add a reference to footnotes “g” and “h” at the end of the title of TABLE 502.3.3(2).</p> <p>Add footnote “g” to read as follows: <u>g. In addition to snow loads shown, the table includes 60 psf of live load.</u></p> <p>Add footnote “h” to read as follows: <u>h. Use of the table shall be permitted for the construction of interior balconies not supporting roof loads.</u></p>		
REASON AND FISCAL IMPACT		
This proposal is in the current IRC and was overlooked. There is no added cost over the current code.		
REVIEW RECOMMENDATION		
Approve 18-0-1 3/16/10		
Disapprove		
Approve as amended		
Further Study		